

Periodic Tests for Electric Elevators

Michigan Department of Licensing and Regulatory Affairs
Bureau of Construction Codes / Elevator Safety Division
P.O. Box 30254, Lansing, MI 48909
Phone: 517-241-9337 / E-Mail: elevsafety@michigan.gov

STATE SERIAL NUMBER:

Authority: 1967 PA 227 | Penalty: Failure to provide the information may result in the denial of your request

ELEVATOR LOCATION (BUILDING NAME)	LOCATION (ADDRESS)	CITY	ZIP CODE
-----------------------------------	--------------------	------	----------

Car Speeds			
Full Load Up _____ FPM	Full Load Down _____ FPM	Empty Up _____ FPM	Empty Down _____ FPM

Category 1 Test Requirement- Yearly	ASME Section	Pass	Fail	N/A
Oil Buffers	8.6.4.19.1			
Safeties	8.6.4.19.2			
Governors	8.6.4.19.3			
Slack Rope Devices on Winding Drum Machines	8.6.4.19.4			
Normal and Final Terminal Stopping Devices	8.6.4.19.5			
Firefighter's Emergency Operation	8.6.4.19.6			
Standby or Emergency Power Operation	8.6.4.19.7			
Power Operation of Door System	8.6.4.19.8			
Broken Rope, Tape, or Chain Switch	8.6.4.19.9			
E/E/PES Electrical Protective Devices	8.6.4.19.10			
Ascending Car Overspeed Protection and Unintended Car Movement	8.6.4.19.11			
Traction Loss Detection Means	8.6.4.19.12			
Broken-Suspension-Member and Residual-Strength Detection Means	8.6.4.19.13			

Category 5 Test Requirement-Every 5 Years	ASME Section	Pass	Fail	N/A
Car and Counterweight Safeties	8.6.4.20.1			
Governors	8.6.4.20.2			
Oil Buffers	8.6.4.20.3			
Braking System	8.6.4.20.4			
Emergency and Standby Power Operation	8.6.4.20.5			
Emergency Terminal Stopping and Speed-Limiting Devices	8.6.4.20.6			
Power Opening of Doors	8.6.4.20.7			
Leveling -Zone and Leveling-Speed	8.6.4.20.8			
Inner Landing Zone	8.6.4.20.9			
Emergency Stopping Distance	8.6.4.20.10			
Emergency Brake	8.6.4.20.11			

<input type="checkbox"/> I Certify the Above Tests Were Performed In Compliance With ASME A17.1 and the Michigan Elevator Rules	
Comments:	
Elevator Journeyperson #	Elevator Journeyperson Signature
Company Conducting Test:	Date: